



afes@ahmedabadcity.gov.in



FORM B 13.3
FIRE SAFETY CERTIFICATE RENEWAL (FSCR)
(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/CFOAMC/2021/00013010
FSC Safety Certificate Renewal (FSCR) No. FSCA/O/CFOAMC/2021/00013010/R1

Date: 18/05/2025

Building Occupancy/Category: Educational (non-residential)

To,

GAMIT JAMESKUMAR JAYANTILAL
SHREEJI IMAGE PUBLIC SCHOOL MEHEMDAVAD ROAD HATHIJAN AHMEDABAD Ahmedabad MC 382445
Fire Region: Ahmedabad MC
Mobile No: 9978121993 **Email ID:** jameskumargamit@gmail.com

We have received Application No. **2025/00122536** dated 13/05/2025 for **Fire Safety Certificate Renewal (FSCR)** - New Building(FSCR)/Existing Building (FSCRe) for the building/premise **SHREEJI IMAGE PUBLIC SCHOOL (name of the Building/ Project)**, as per below mentioned details:

1. **TP Number:**
2. **FP Number:**
3. **Survey Number:**
4. **Village Name:** AHMEDABAD
5. **Name of Block(s):** 1

The building/premise was inspected on **18/05/2025** and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on **18/05/2025**
2. Six monthly inspection was done on **18/05/2025**

The Fire Safety Certificate is renewed for a period of **two (2)** years upto **18/05/2027** in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.

This is issued based on the verification and approval of the RFO/CFO dated: **17/05/2025 9:59:06 PM**



Digitally Verified

Digitally verified by: Jagdish Solanki
Fire Safety Officer - General (FSO-G)
2021/000518
Reviewed by : CFO Ahmedabad MC
Date: 18/05/2025
Time: 10:58 AM



FSCA/O/CFOAMC/2021/00013010/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.